

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和2年4月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	水	8:39	10.3					7.5	0.4	
2	木	8:37	10.8	43	74	9.8	0.12	7.6	1.5	38.6
3	金	8:45	10.4					7.7	0.6	
4	土									
5	日									
6	月	8:46	11.1					7.6	1.1	
7	火	8:40	10.0	39	51	9.2	<0.03	7.5	0.3	34.8
8	水	8:40	10.0					7.4	0.3	
9	木	8:38	11.4					7.8	0.6	
10	金	11:20	12.0					7.7	0.7	
11	土									
12	日									
13	月	8:38	11.9					7.8	0.7	
14	火	8:43	10.8	42	68	10	0.10	7.6	1.6	37.5
15	水	8:47	10.4					7.6	1.1	
16	木	8:41	10.8					7.5	1.2	
17	金	8:37	11.1					7.5	0.6	
18	土	8:38	12.2					7.5	0.5	
19	日									
20	月	8:38	12.2					7.5	0.5	
21	火	8:40	12.1	39	63	9.1	<0.03	7.4	0.8	35.0
22	水	8:41	12.2					7.5	0.6	
23	木	8:39	11.6					7.4	0.8	
24	金	8:49	11.8					7.6	1.1	
25	土									
26	日									
27	月	8:37	12.7					7.7	1.7	
28	火	8:55	12.2	39	59	9.2	0.03	7.4	0.9	34.7
29	水									
30	木	8:39	12.1					7.3	0.5	
-	-									
平均	—		11.4	40	63	9.5	0.05	7.6	0.8	36.1
最高	—		12.7	43	74	10	0.12	7.8	1.7	38.6
最低	—		10.0	39	51	9.1	<0.03	7.3	0.3	34.7
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和2年5月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分	°C	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	金	8:41	14.1					7.7	2.8	
2	土									
3	日									
4	月									
5	火									
6	水									
7	木	8:41	14.6	40	65	9.4	<0.03	7.8	0.6	35.1
8	金	8:37	14.9					7.8	1.1	
9	土									
10	日									
11	月	8:39	14.2					7.5	0.5	
12	火	8:41	13.6	38	60	9.2	<0.03	7.4	0.5	33.8
13	水	8:39	15.8					8.0	1.0	
14	木	8:38	15.3					7.9	0.7	
15	金	8:37	16.9					8.5	0.3	
16	土									
17	日									
18	月	8:39	15.2					8.0	1.6	
19	火	8:37	16.4	39	68	9.1	<0.03	8.3	1.5	35.5
20	水	8:37	15.4					7.7	1.2	
21	木	8:41	15.6					7.6	1.0	
22	金	8:35	16.3					8.3	1.1	
23	土									
24	日									
25	月	8:36	18.4					8.6	1.3	
26	火	8:42	17.8	40	68	9.3	<0.03	8.6	1.5	36.0
27	水	8:37	18.3					8.7	1.7	
28	木	8:37	19.0					8.5	1.3	
29	金	8:37	17.8					8.0	1.4	
30	土									
31	日									
平均		—	16.1	39	65	9.3	<0.03	8.1	1.2	35.1
最高		—	19.0	40	68	9.4	<0.03	8.7	2.8	36.0
最低		—	13.6	38	60	9.1	<0.03	7.4	0.3	33.8
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和2年6月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分	°C	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	月	8:40	18.3					8.0	1.6	
2	火	8:37	19.2	39	72	9.3	<0.03	8.8	1.3	35.3
3	水	8:37	19.8					8.6	1.7	
4	木	8:37	19.8					8.7	1.6	
5	金	8:50	18.8					8.0	1.5	
6	土									
7	日									
8	月	8:38	20.5					8.7	1.5	
9	火	8:35	20.7	39	69	9.2	<0.03	8.8	1.2	35.0
10	水	8:47	21.0					8.9	1.3	
11	木	8:44	22.2					8.8	1.2	
12	金	8:37	21.5					8.8	1.0	
13	土									
14	日									
15	月	8:40	22.0					8.2	2.3	
16	火	8:39	20.8	38	68	9.0	<0.03	8.6	1.1	35.1
17	水	8:37	22.8					8.3	1.6	
18	木	8:43	22.0					8.6	1.1	
19	金	8:39	21.7					8.1	1.4	
20	土									
21	日									
22	月	8:45	21.9					8.6	1.4	
23	火	8:42	22.2	41	73	8.9	0.03	8.5	1.9	37.2
24	水	8:39	22.3					8.6	1.2	
25	木	8:37	22.6					8.7	1.1	
26	金	8:41	22.7					8.6	1.0	
27	土									
28	日									
29	月	8:41	23.9					8.5	1.2	
30	火	8:37	23.6	38	67	8.9	<0.03	8.6	0.9	36.0
-	-									
平均		—	21.4	39	70	9.1	<0.03	8.5	1.4	35.7
最高		—	23.9	41	73	9.3	0.03	8.9	2.3	37.2
最低		—	18.3	38	67	8.9	<0.03	8.0	0.9	35.0
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和2年7月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分	°C	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	水	8:55	23.4					8.6	1.0	
2	木	8:48	23.8					8.7	1.1	
3	金	8:36	23.7					8.6	1.0	
4	土									
5	日									
6	月	8:37	23.2					8.6	1.4	
7	火	8:38	23.4	39	70	8.6	<0.03	8.7	1.1	35.2
8	水	8:41	23.3					8.5	2.5	
9	木	8:37	23.2					8.1	5.0	
10	金	8:35	23.2					8.2	2.0	
11	土									
12	日									
13	月	8:41	23.3					7.7	2.6	
14	火	8:37	23.0	40	73	8.0	<0.03	7.7	2.1	35.8
15	水	8:38	22.8					8.0	1.5	
16	木	8:37	22.9					7.8	1.5	
17	金	8:37	23.1					7.7	1.6	
18	土									
19	日									
20	月	8:38	23.5					8.2	1.0	
21	火	8:36	23.8	40	69	8.4	<0.03	8.1	1.1	36.8
22	水	8:49	24.7					8.3	1.1	
23	木									
24	金									
25	土									
26	日									
27	月	8:38	24.6					8.0	1.1	
28	火	8:42	24.5	37	65	8.1	<0.03	8.0	1.0	33.3
29	水	8:43	24.6					7.6	1.3	
30	木	8:47	24.4					7.6	1.1	
31	金	8:38	24.8					7.5	1.3	
平均		—	23.7	39	69	8.3	<0.03	8.1	1.6	35.3
最高		—	24.8	40	73	8.6	<0.03	8.7	5.0	36.8
最低		—	22.8	37	65	8.0	<0.03	7.5	1.0	33.3
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和2年8月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分	°C	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	土									
2	日									
3	月	8:39	26.3					8.2	0.8	
4	火	14:16	27.8	39	67	8.3	<0.03	8.2	0.8	34.8
5	水	8:39	26.6					8.0	0.9	
6	木	8:42	26.5					7.6	1.1	
7	金	8:38	27.8					7.9	0.8	
8	土									
9	日									
10	月									
11	火	8:49	28.8	38	72	8.3	<0.03	7.5	0.7	35.0
12	水									
13	木									
14	金									
15	土									
16	日									
17	月	8:40	27.8					7.1	1.1	
18	火	8:38	29.2	39	71	8.6	<0.03	7.6	0.9	35.2
19	水	8:38	29.2					7.5	1.4	
20	木	8:36	29.4					7.4	0.9	
21	金	8:38	29.4					7.7	0.8	
22	土									
23	日									
24	月	8:41	29.2					7.5	0.8	
25	火	8:38	29.3	38	66	8.4	<0.03	7.5	0.7	34.5
26	水	8:39	29.3					7.5	0.9	
27	木	8:36	29.2					7.6	0.8	
28	金	8:40	29.4					7.6	0.6	
29	土									
30	日									
31	月	8:39	29.8					7.5	0.6	
平均	—	—	28.5	39	69	8.4	<0.03	7.6	0.9	34.9
最高	—	—	29.8	39	72	8.6	<0.03	8.2	1.4	35.2
最低	—	—	26.3	38	66	8.3	<0.03	7.1	0.6	34.5
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和2年9月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	火	8:38	29.9	38	66	8.4	<0.03	7.6	0.7	34.6
2	水	8:37	29.4					7.6	0.8	
3	木	8:41	28.9					7.5	0.8	
4	金	8:38	28.9					7.6	0.8	
5	土									
6	日									
7	月	8:38	26.6					7.2	1.1	
8	火	8:38	27.5	38	73	8.4	<0.03	7.5	0.6	34.1
9	水	8:40	27.5					7.5	0.7	
10	木	8:36	27.2					7.5	0.7	
11	金	8:40	27.2					7.5	0.9	
12	土									
13	日									
14	月	8:39	26.6					7.5	1.1	
15	火	8:37	26.0	39	73	8.7	<0.03	7.5	1.4	35.5
16	水	8:36	26.5					7.5	0.8	
17	木	8:38	26.5					7.3	1.0	
18	金	8:56	26.3					7.3	1.0	
19	土									
20	日									
21	月									
22	火									
23	水	8:38	24.9	40	69	9.0	<0.03	7.7	0.9	35.8
24	木	8:38	25.3					7.5	0.9	
25	金	8:45	25.3					7.5	1.0	
26	土									
27	日									
28	月	8:43	23.4					7.5	1.9	
29	火	8:42	23.5	39	66	8.5	<0.03	7.5	0.9	35.5
30	水	8:37	23.7					7.4	0.9	
-	-									
平均	—		26.6	39	69	8.6	<0.03	7.5	0.9	35.1
最高	—		29.9	40	73	9.0	<0.03	7.7	1.9	35.8
最低	—		23.4	38	66	8.4	<0.03	7.2	0.6	34.1
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和2年10月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	木	8:38	23.6					7.5	0.7	
2	金	8:38	23.2					7.3	1.0	
3	土									
4	日									
5	月	8:38	23.2					7.3	0.8	
6	火	8:39	22.2	41	73	9.0	<0.03	7.4	1.6	37.2
7	水	8:38	22.0					7.4	1.0	
8	木	8:37	21.9					7.4	0.9	
9	金	8:39	21.2					7.3	1.1	
10	土									
11	日									
12	月	8:38	21.5					7.3	1.0	
13	火	8:39	22.0	38	71	8.4	<0.03	7.4	1.0	35.2
14	水	8:38	21.6					7.4	1.3	
15	木	8:36	21.3					7.7	1.6	
16	金	8:37	20.8					7.6	1.7	
17	土									
18	日									
19	月	8:38	19.6					7.5	0.9	
20	火	8:40	19.3	38	72	8.5	<0.03	7.6	1.0	33.9
21	水	8:37	19.5					7.8	1.2	
22	木	8:36	19.6					7.7	1.6	
23	金	8:41	19.3					7.5	1.9	
24	土									
25	日									
26	月	8:37	18.3					7.6	1.2	
27	火	11:47	18.3	39	72	8.6	<0.03	7.8	1.1	35.5
28	水	8:35	18.4					8.0	1.1	
29	木	8:38	18.1					8.0	1.2	
30	金	8:38	17.7					7.9	1.6	
31	土									
平均		—	20.6	39	72	8.6	<0.03	7.6	1.2	35.5
最高		—	23.6	41	73	9.0	<0.03	8.0	1.9	37.2
最低		—	17.7	38	71	8.4	<0.03	7.3	0.7	33.9
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和2年11月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分								
1	日									
2	月	8:37	17.4					7.9	1.0	
3	火									
4	水	8:38	16.1	41	68	9.0	<0.03	7.5	3.1	36.5
5	木	8:40	16.3					7.5	1.4	
6	金	8:37	16.3					7.6	1.0	
7	土									
8	日									
9	月	8:37	16.2					7.4	1.0	
10	火	8:38	15.6	39	62	8.8	<0.03	7.5	1.0	34.8
11	水	8:37	16.1					7.5	0.9	
12	木	8:41	14.9					7.5	1.2	
13	金	8:38	15.2					7.5	0.5	
14	土									
15	日									
16	月	8:37	15.6					7.5	0.7	
17	火	8:38	15.6	40	67	9.6	<0.03	7.6	0.8	35.4
18	水	8:39	15.7					7.5	0.8	
19	木	8:38	15.9					7.5	0.8	
20	金	8:41	16.2					7.4	1.0	
21	土									
22	日									
23	月									
24	火	8:37	14.8	40	65	9.1	<0.03	7.4	1.0	34.8
25	水	8:41	14.6					7.4	0.8	
26	木	8:41	14.6					7.4	0.7	
27	金	8:37	14.6					7.3	0.5	
28	土									
29	日									
30	月	8:39	14.0					7.4	0.7	
-	-									
平均	—		15.6	40	66	9.1	<0.03	7.5	1.0	35.4
最高	—		17.4	41	68	9.6	<0.03	7.9	3.1	36.5
最低	—		14.0	39	62	8.8	<0.03	7.3	0.5	34.8
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和2年12月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分								
1	火	8:40	13.6	38	64	12	<0.03	7.4	0.6	32.2
2	水	8:39	13.5					7.4	0.7	
3	木	8:37	13.7					7.4	0.6	
4	金	8:37	13.1					7.4	1.0	
5	土									
6	日									
7	月	8:38	12.9					7.5	0.4	
8	火	8:37	13.0	39	66	8.8	<0.03	7.5	0.5	34.5
9	水	8:40	12.8					7.4	0.5	
10	木	8:37	12.5					7.4	0.5	
11	金	8:40	12.7					7.4	0.4	
12	土									
13	日									
14	月	8:37	12.3					7.4	0.5	
15	火	8:38	11.3	38	66	8.8	<0.03	7.4	0.9	34.6
16	水	8:38	10.0					7.5	0.9	
17	木	8:40	9.0					7.5	1.6	
18	金	8:39	9.8					7.5	0.9	
19	土									
20	日									
21	月	8:50	9.7					7.4	0.6	
22	火	8:37	9.8	39	66	9.2	<0.03	7.4	0.5	35.1
23	水	8:39	10.0					7.4	0.4	
24	木	8:37	9.8					7.4	0.5	
25	金	8:42	10.0					7.4	0.3	
26	土									
27	日									
28	月	8:39	9.9					7.3	0.3	
29	火									
30	水									
31	木									
平均		—	11.5	39	66	9.7	<0.03	7.4	0.6	34.1
最高		—	13.7	39	66	12	<0.03	7.5	1.6	35.1
最低		—	9.0	38	64	8.8	<0.03	7.3	0.3	32.2
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和3年1月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分								
1	金									
2	土									
3	日									
4	月	8:42	7.9					7.4	1.8	
5	火	8:37	8.5	40	63	9.2	<0.03	7.4	0.7	35.5
6	水	8:39	8.8					7.3	0.4	
7	木	8:38	8.6					7.3	0.8	
8	金	9:14	6.9					7.5	2.4	
9	土									
10	日									
11	月									
12	火	8:41	7.6	39	66	9.1	<0.03	7.2	0.5	35.0
13	水	8:38	7.6					7.2	0.4	
14	木	8:39	7.8					7.1	0.4	
15	金	8:43	8.1					7.1	0.3	
16	土									
17	日									
18	月	8:38	7.8					7.2	0.8	
19	火	8:38	7.4	39	71	9.2	<0.03	7.3	0.9	35.6
20	水	8:38	6.7					7.5	1.3	
21	木	8:38	7.2					7.4	0.7	
22	金	8:41	8.0					7.2	0.5	
23	土									
24	日									
25	月	8:40	8.3					7.4	1.4	
26	火	8:38	8.1	44	77	9.8	<0.03	7.4	1.2	39.3
27	水	8:40	8.8					7.2	0.5	
28	木	8:45	8.7					7.5	1.3	
29	金	8:41	8.0					7.5	3.3	
30	土									
31	日									
平均		—	7.9	41	69	9.3	<0.03	7.3	1.0	36.4
最高		—	8.8	44	77	9.8	<0.03	7.5	3.3	39.3
最低		—	6.7	39	63	9.1	<0.03	7.1	0.3	35.0
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和3年2月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	月	8:40	7.4					7.4	1.3	
2	火	8:38	8.0	38	64	9.6	<0.03	7.4	0.8	
3	水	8:38	7.7					7.4	2.0	
4	木	8:37	7.4					7.3	0.9	
5	金	8:38	7.3					7.4	1.4	
6	土									
7	日									
8	月	8:39	8.1					7.4	0.4	
9	火	8:38	7.4	41	69	10	<0.03	7.5	1.4	36.7
10	水	8:42	7.5					7.5	1.0	
11	木									
12	金	8:38	8.2					7.5	0.8	
13	土									
14	日									
15	月	8:39	8.8					7.4	0.6	
16	火	8:38	8.9	40	87	13	0.06	7.2	9.9	34.7
17	水	8:38	8.2					7.4	12	
18	木	8:38	7.2					7.5	5.1	
19	金	8:40	7.1					7.5	4.2	
20	土									
21	日									
22	月	8:39	8.4					7.4	0.7	
23	火									
24	水	8:37	8.2	43	79	10	<0.03	7.6	1.4	37.7
25	木	8:37	7.7					7.4	1.1	
26	金	8:39	8.1					7.4	1.2	
27	土									
28	日									
-	-									
-	-									
-	-									
平均		—	7.9	41	75	11	<0.03	7.4	2.6	36.4
最高		—	8.9	43	87	13	0.06	7.6	12	37.7
最低		—	7.1	38	64	9.6	<0.03	7.2	0.4	34.7
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和3年3月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分								
1	月	8:37	8.0					7.4	1.6	
2	火	8:38	9.0	43	71	9.6	0.04	7.4	2.0	37.5
3	水	8:37	7.9					7.5	2.8	
4	木	8:38	7.9					7.4	1.2	
5	金	8:42	8.6					7.4	1.9	
6	土									
7	日									
8	月	8:38	8.8					7.4	3.0	
9	火	8:38	8.6	41	64	9.2	0.03	7.4	3.1	35.5
10	水	8:37	9.2					7.5	2.8	
11	木	8:51	8.6					7.4	1.9	
12	金	8:38	9.1					7.6	2.4	
13	土									
14	日									
15	月	8:36	9.1					7.5	1.5	
16	火	8:40	9.5	40	63	9.4	<0.03	7.6	1.4	36.3
17	水	8:39	9.6					7.6	1.4	
18	木	8:36	9.2					7.5	1.8	
19	金	8:39	9.4					7.5	1.2	
20	土									
21	日									
22	月	8:37	10.4					7.5	2.5	
23	火	8:38	9.8	41	69	9.3	<0.03	7.5	1.7	35.7
24	水	8:38	9.7					7.4	1.2	
25	木	8:38	10.0					7.3	1.4	
26	金	8:41	9.9					7.4	1.3	
27	土									
28	日									
29	月	8:37	10.7					7.4	1.1	
30	火	8:42	11.3	40	65	9.2	<0.03	7.5	1.1	34.9
31	水	8:36	11.6					7.6	0.9	
平均		—	9.4	41	66	9.3	<0.03	7.5	1.8	36.0
最高		—	11.6	43	71	9.6	0.04	7.6	3.1	37.5
最低		—	7.9	40	63	9.2	<0.03	7.3	0.9	34.9
記事										