

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和6年4月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	月	8:46	11.3					7.8	1.8	
2	火	8:38	10.3	40	68	9.1	0.06	7.6	1.2	37.1
3	水	8:49	10.4					7.7	1.0	
4	木	8:46	11.3					7.7	1.7	
5	金	8:45	11.5					7.9	2.1	
6	土	8:00	11.3					7.9	1.1	
7	日	8:00	11.5					8.0	1.0	
8	月	8:46	12.0					7.8	0.7	
9	火	9:00	14.0	41	69	8.6	0.11	8.1	2.1	39.9
10	水	8:46	12.1					7.8	1.6	
11	木	8:47	11.3					7.7	0.7	
12	金	8:45	12.1					7.8	0.8	
13	土	8:00	13.1					8.1	1.7	
14	日	8:00	12.2					7.6	0.9	
15	月	8:49	12.6					7.6	0.7	
16	火	9:20	13.9	42	70	9.5	<0.03	7.9	0.6	
17	水	8:46	13.7					7.7	0.7	
18	木	8:46	13.7					7.8	0.5	
19	金	8:46	14.5					8.1	0.5	
20	土	8:00	13.9					7.9	0.6	
21	日	8:00	14.3					7.8	0.6	
22	月	8:45	14.2					7.6	0.6	
23	火	8:43	14.0	38	68	9.0	0.03	7.7	0.5	35.6
24	水	8:46	14.2					7.7	0.6	
25	木	8:45	14.4					7.9	0.4	
26	金	8:45	13.5					7.6	0.6	
27	土	8:00	14.3					7.7	0.6	
28	日	8:00	14.9					7.8	1.1	
29	月	8:00	15.3					7.9	0.9	
30	火	8:10	14.1	38	66	9.0	0.05	7.7	1.1	35.6
-	-									
平均		—	13.0	40	68	9.0	0.05	7.8	1.0	37.1
最高		—	15.3	42	70	9.5	0.11	8.1	2.1	39.9
最低		—	10.3	38	66	8.6	<0.03	7.6	0.4	35.6
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和6年5月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分	°C	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	水	8:46	16.0					7.9	1.8	
2	木	8:46	16.3					7.8	2.6	
3	金	8:00	15.8					7.8	0.9	
4	土	8:00	16.0					7.7	0.6	
5	日	8:00	16.6					8.0	0.6	
6	月	8:00	17.0					8.2	0.7	
7	火	8:47	17.4	38	64	8.9	0.04	7.9	0.6	36.7
8	水	8:46	16.6					7.9	0.9	
9	木	8:45	16.1					7.9	1.8	
10	金	8:47	15.8					7.9	1.6	
11	土	8:00	15.9					8.0	0.8	
12	日	8:00	16.7					8.0	0.7	
13	月	8:38	16.6					8.0	0.8	
14	火	8:48	16.1	39	67	9.2	0.05	8.1	1.1	
15	水	8:45	16.5					8.0	0.9	
16	木	8:46	17.0					8.0	0.9	
17	金	8:46	16.9					8.1	1.4	
18	土	8:00	17.2					8.4	1.2	
19	日	8:00	18.2					8.6	1.3	
20	月	8:46	18.0					8.8	1.1	
21	火	8:49	18.5	38	69	9.0	0.09	8.7	1.0	34.7
22	水	8:36	18.5					8.4	1.0	
23	木	8:45	18.9					8.7	0.9	
24	金	8:46	18.7					8.5	0.8	
25	土	8:00	20.0					8.9	1.3	
26	日	8:00	19.4					8.8	1.3	
27	月	8:43	19.1					8.7	0.9	
28	火	8:49	19.0	39	71	9.0	0.10	8.5	0.9	35.9
29	水	8:46	18.6					8.1	4.3	
30	木	8:45	18.1					8.5	1.1	
31	金	8:45	18.3					8.8	1.1	
平均	—	—	17.4	39	68	9.0	0.07	8.2	1.2	35.8
最高	—	—	20.0	39	71	9.2	0.10	8.9	4.3	36.7
最低	—	—	15.8	38	64	8.9	0.04	7.7	0.6	34.7
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和6年6月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	土	8:00	18.3					8.5	1.2	
2	日	8:00	18.8					8.8	1.2	
3	月	8:48	18.5					8.5	1.1	
4	火	8:47	18.5	38	69	8.9	0.12	8.4	1.2	34.9
5	水	8:49	20.0					8.8	1.4	
6	木	8:46	19.6					8.8	1.1	
7	金	8:47	19.8					8.8	1.1	
8	土	8:00	19.9					8.8	1.2	
9	日	8:00	20.4					8.9	1.3	
10	月	8:40	20.7					8.9	0.9	
11	火	8:43	21.2	39	73	8.9	0.05	8.9	0.9	36.0
12	水	8:58	21.6					8.7	0.9	
13	木	8:46	22.0					9.1	0.8	
14	金	8:46	22.0					8.9	0.9	
15	土	8:00	21.9					8.8	1.1	
16	日	8:00	23.4					8.9	0.8	
17	月	8:46	23.5					8.9	0.8	
18	火	8:46	22.6	39	71	8.6	0.05	8.8	0.7	35.6
19	水	8:46	22.1					8.3	3.7	
20	木	8:40	22.5					8.2	1.7	
21	金	8:46	22.4					8.4	1.2	
22	土	8:00	23.3					8.4	1.0	
23	日	8:00	23.4					8.5	0.9	
24	月	8:46	23.5					8.4	1.6	
25	火	8:45	23.9	39	77	8.3	0.09	8.4	1.0	36.2
26	水	8:47	23.8					8.3	1.2	
27	木	8:50	23.2					8.0	0.9	
28	金	8:46	23.4					7.9	0.7	
29	土	8:00	22.9					7.8	3.3	
30	日	8:00	23.8					8.1	1.4	
-	-									
平均	—		21.7	39	73	8.7	0.08	8.6	1.2	35.7
最高	—		23.9	39	77	8.9	0.12	9.1	3.7	36.2
最低	—		18.3	38	69	8.3	0.05	7.8	0.7	34.9
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和6年7月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	月	8:59	24.3					8.3	0.9	
2	火	8:48	24.0	42	66	8.0	0.08	7.8	1.1	37.8
3	水	8:46	24.1					7.9	0.9	
4	木	8:45	24.9					7.9	0.9	
5	金	8:44	25.1					7.9	1.0	
6	土	8:00	26.4					8.4	0.9	
7	日	8:00	26.1					8.0	0.9	
8	月	8:45	27.5	40	68	8.4	0.05	8.1	0.7	35.8
9	火	8:40	26.9					7.7	0.9	
10	水	8:44	26.6					7.5	0.8	
11	木	8:46	26.9					7.8	0.5	
12	金	8:46	26.7					7.8	0.5	
13	土	8:00	26.3					7.9	0.8	
14	日	8:00	26.2					7.7	0.7	
15	月	8:00	26.2					7.9	0.7	
16	火	8:46	25.3	41	70	7.7	0.09	7.4	1.3	36.4
17	水	8:40	25.9					7.8	2.6	
18	木	9:40	26.4					8.0	2.8	
19	金	8:47	27.5					8.3	1.5	
20	土	8:00	28.2					8.3	1.0	
21	日	8:00	27.2					7.7	1.5	
22	月	8:41	28.3	38	64	7.8	0.06	7.9	0.8	34.9
23	火	8:38	28.9					8.0	0.5	
24	水	8:36	28.9					7.8	0.6	
25	木	8:42	28.8					7.9	0.5	
26	金	8:24	28.3					7.7	0.6	
27	土	8:00	29.0					8.1	0.5	
28	日	8:00	28.8					7.8	0.8	
29	月	8:38	28.9	39	68	8.5	0.06	7.7	0.7	35.6
30	火	8:39	29.7					7.8	0.8	
31	水	8:36	29.3					7.9	0.7	
平均		—	27.0	41	68	8.0	0.07	7.9	0.9	36.1
最高		—	29.7	42	70	8.4	0.09	8.4	2.8	37.8
最低		—	24.0	40	66	7.7	0.05	7.4	0.5	34.9
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和6年8月

		採水時刻	水温 °C	硬度 mg/L	蒸発 残留物 mg/L	塩素 イオン mg/L	鉄 イオン mg/L	pH値	濁度 度	総アル カリ度 mg/L
日	曜	時：分								
1	木	8:42	29.4					7.9	1.1	
2	金	8:52	29.9					7.7	0.7	
3	土	8:00	29.9					7.7	0.5	
4	日	8:00	30.2					7.8	0.6	
5	月	9:03	31.0					7.8	0.4	
6	火	8:41	30.6	37	69	8.2	0.04	7.6	0.5	33.7
7	水	8:40	30.7					7.7	0.5	
8	木	8:39	30.3					7.7	0.5	
9	金	8:49	30.1					7.5	0.6	
10	土	8:00	30.1					7.7	1.3	
11	日	8:00	30.2					7.7	1.1	
12	月	8:00	29.8					7.5	0.9	
13	火	8:00	29.8					7.5	0.6	
14	水	8:00	30.1					7.6	0.5	
15	木	8:00	30.3					7.6	0.5	
16	金	8:41	30.5	38	69	8.3	<0.03	7.6	0.6	34.4
17	土	8:00	29.8					7.5	1.5	
18	日	8:00	29.5					7.6	1.0	
19	月	8:40	29.7	36	68	8.2	0.03	7.5	0.7	33.6
20	火	8:37	29.4					7.6	0.6	
21	水	8:40	29.5					7.6	0.6	
22	木	8:54	29.5					7.6	0.8	
23	金	8:39	29.9					7.6	0.6	
24	土	8:00	30.1					7.6	0.5	
25	日	8:00	30.3					7.6	0.4	
26	月	8:42	30.7	37	67	8.2	0.03	7.7	0.4	34.4
27	火	8:41	29.7					7.5	0.5	
28	水	8:50	30.1					7.7	0.3	
29	木	8:37	29.5					7.7	0.4	
30	金	9:01	28.6					7.6	0.7	
31	土	8:00	28.2					7.6	0.8	
平均	—	—	29.9	37	68	8.2	<0.03	7.6	0.7	34.0
最高	—	—	31.0	38	69	8.3	0.04	7.9	1.5	34.4
最低	—	—	28.2	36	67	8.2	<0.03	7.5	0.3	33.6
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和6年9月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	日	8:00	28.0					7.6	0.8	
2	月	8:51	28.1					7.6	0.7	
3	火	8:38	28.4	36	65	8.3	0.05	7.6	0.6	34.3
4	水	8:52	28.1					7.6	0.9	
5	木	8:37	28.4					7.6	0.8	
6	金	8:43	28.4					7.6	0.7	
7	土	8:00	28.6					7.6	0.6	
8	日	8:00	28.9					7.6	0.6	
9	月	8:42	29.4	37	68	8.3	0.03	7.6	0.7	34.4
10	火	8:46	29.1					7.6	0.6	
11	水	8:45	29.1					7.7	0.5	
12	木	8:40	29.6					7.7	0.4	
13	金	8:38	29.8					7.7	0.4	
14	土	8:00	29.8					7.7	0.5	
15	日	8:00	29.7					7.6	0.5	
16	月	8:00	29.7					7.8	0.6	
17	火	8:46	29.7	37	67	8.4	0.04	7.7	0.5	35.0
18	水	8:44	30.0					7.7	0.5	
19	木	8:41	30.2					7.8	0.4	
20	金	8:39	30.1					7.6	0.5	
21	土	8:00	30.2					7.8	0.5	
22	日	8:00	29.8					7.7	0.5	
23	月	8:00	27.7					7.5	2.5	
24	火	8:38	27.9	36	68	8.7	0.04	7.6	1.0	35.4
25	水	8:41	27.4					7.7	0.7	
26	木	8:37	27.6					7.7	0.6	
27	金	8:41	27.8					7.6	0.6	
28	土	8:00	27.5					7.5	1.0	
29	日	8:00	26.9					7.6	0.9	
30	月	8:37	26.8					7.6	0.6	
-	-									
平均	—		28.8	37	67	8.4	0.04	7.6	0.7	34.8
最高	—		30.2	37	68	8.7	0.05	7.8	2.5	35.4
最低	—		26.8	36	65	8.3	0.03	7.5	0.4	34.3
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和6年10月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	火	8:43	26.7					7.5	0.6	
2	水	8:48	26.9					7.6	0.8	
3	木	8:42	26.7	38	67	8.5	0.04	7.8	0.7	35.1
4	金	8:40	26.1					7.6	1.0	
5	土	8:00	25.2					7.7	1.4	
6	日	8:00	25.3					7.8	1.0	
7	月	8:42	25.6	38	66	8.5	0.03	7.9	0.8	34.2
8	火	8:36	25.4					7.9	0.7	
9	水	8:45	24.1					7.8	2.0	
10	木	8:37	24.0					7.8	1.3	
11	金	8:38	24.0					7.9	0.8	
12	土	8:00	23.4					7.8	1.4	
13	日	8:00	23.8					7.9	0.9	
14	月	8:00	23.8					7.8	0.8	
15	火	8:56	23.9	39	65	8.6	0.03	7.8	0.8	36.0
16	水	8:37	23.7					7.7	0.8	
17	木	8:39	23.7					7.8	0.6	
18	金	8:42	24.0					7.7	0.8	
19	土	8:00	23.9					7.7	0.8	
20	日	8:00	22.7					7.7	9.5	
21	月	8:39	21.9	39	67	8.8	0.05	7.7	1.8	35.1
22	火	8:37	21.8					7.8	1.2	
23	水	8:41	22.4					7.8	0.9	
24	木	8:36	22.3					7.8	1.4	
25	金	8:38	21.8					7.8	1.5	
26	土	8:00	21.8					7.9	1.1	
27	日	8:00	21.7					7.8	1.0	
28	月	8:43	21.6	39	65	8.7	0.05	7.8	1.1	35.0
29	火	8:20	21.0					7.8	1.4	
30	水	8:44	20.8					7.7	1.3	
31	木	8:36	19.6					7.8	2.0	
平均		—	23.5	39	66	8.6	0.04	7.8	1.4	35.1
最高		—	26.9	39	67	8.8	0.05	7.9	9.5	36.0
最低		—	19.6	38	65	8.5	0.03	7.5	0.6	34.2
記事										

# 水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和6年11月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	金	8:40	20.4					7.8	0.8	
2	土	8:00	20.2					7.8	0.9	
3	日	8:00	19.3					7.8	5.8	
4	月	8:00	18.5					7.8	2.4	
5	火	8:38	19.5	38	67	8.4	0.05	7.8	1.2	35.1
6	水	8:51	19.1					7.8	1.6	
7	木	8:36	18.1					7.8	3.9	
8	金	8:47	16.5					7.8	2.5	
9	土	8:00	16.4					7.9	1.2	
10	日	8:00	16.5					8.0	1.0	
11	月	8:37	17.9					7.9	1.0	
12	火	8:39	17.5	39	66	8.5	0.04	7.9	0.9	35.2
13	水	8:38	18.0					7.9	0.9	
14	木	8:45	17.3					7.8	1.1	
15	金	8:44	17.9					7.9	1.1	
16	土	8:00	17.8					8.0	1.1	
17	日	8:00	18.1					7.9	1.0	
18	月	8:44	17.6	42	71	10	0.17	7.8	3.7	39.1
19	火	8:45	15.2					7.8	3.9	
20	水	7:45	14.9					7.8	1.4	
21	木	8:45	14.8					7.8	1.0	
22	金	8:26	15.4					7.8	1.0	
23	土	8:00	15.0					7.8	2.5	
24	日	8:00	14.4					7.9	1.2	
25	月	8:45	14.4	39	65	8.7	0.04	7.8	1.1	35.4
26	火	8:49	14.6					7.8	0.8	
27	水	8:45	15.1					7.8	1.2	
28	木	8:45	14.2					7.8	1.1	
29	金	8:44	13.7					7.9	1.1	
30	土	8:00	13.4					7.9	1.1	
-	-									
平均	—		16.7	40	67	8.9	0.08	7.8	1.7	36.2
最高	—		20.4	42	71	10	0.17	8.0	5.8	39.1
最低	—		13.4	38	65	8.4	0.04	7.8	0.8	35.1
記事										