

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和7年4月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	火	8:20	10.2					7.8	1.1	
2	水	13:24	10.6	41	71	9.5	<0.03	7.7	0.9	35.8
3	木	8:21	10.5					7.7	0.8	
4	金	8:24	10.9					7.9	0.9	
5	土	8:00	10.4					7.8	1.1	
6	日	8:00	11.1					7.7	0.8	
7	月	8:23	11.5					7.8	1.0	
8	火	8:35	11.2					7.7	0.9	
9	水	8:35	12.4	42	71	10	<0.03	7.8	0.9	37.3
10	木	8:24	12.2					7.7	0.9	
11	金	8:24	12.1					7.6	0.8	
12	土	8:00	12.9					7.9	0.9	
13	日	8:00	12.7					7.6	0.8	
14	月	13:28	12.5					7.8	1.3	
15	火	8:44	12.6	41	70	9.4	0.06	7.7	0.9	36.4
16	水	8:36	12.0					7.7	0.8	
17	木	8:23	12.6					7.7	0.9	
18	金	8:22	13.6					7.7	0.7	
19	土	8:00	14.5					7.7	0.8	
20	日	8:00	15.2					7.7	0.7	
21	月	8:21	15.5	39	69	9.2	0.03	7.7	0.7	35.9
22	火	9:00	14.2					7.6	0.7	
23	水	8:24	13.6					7.6	0.5	
24	木	8:25	14.7					7.7	0.6	
25	金	8:24	13.9					7.7	0.6	
26	土	8:00	14.3					7.7	1.3	
27	日	8:00	13.6					7.6	1.2	
28	月	8:25	14.2	38	67	9.1	<0.03	7.7	1.1	34.4
29	火	8:00	14.1					7.7	1.4	
30	水	8:24	14.2					7.7	1.2	
-	-									
平均		—	12.8	40	70	9.4	<0.03	7.7	0.9	36.0
最高		—	15.5	42	71	10	0.06	7.9	1.4	37.3
最低		—	10.2	38	67	9.1	<0.03	7.6	0.5	34.4
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和7年5月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	木	8:45	14.5					7.7	1.5	
2	金	8:23	14.3	39	64	9.0	0.04	7.6	1.3	34.7
3	土	8:00	14.6					7.7	1.5	
4	日	8:00	14.9					7.7	1.3	
5	月	8:00	14.4					7.6	1.5	
6	火	8:00	15.4					7.8	2.6	
7	水	8:25	15.3					7.8	2.0	
8	木	8:25	15.2					7.8	2.0	
9	金	8:24	15.6					7.6	4.5	
10	土	8:00	15.5					7.6	2.4	
11	日	8:00	16.2					7.7	2.5	
12	月	8:39	15.1					7.5	1.4	
13	火	8:43	15.7	39	66	8.9	0.08	7.6	2.4	34.6
14	水	8:38	16.1					7.6	2.0	
15	木	8:25	16.3					7.8	1.6	
16	金	8:23	16.4					7.8	1.3	
17	土	8:00	16.7					7.9	1.4	
18	日	8:00	19.0					8.1	2.0	
19	月	8:25	19.2	40	70	9.1	0.05	8.0	1.6	36.6
20	火	8:40	18.2					7.8	1.3	
21	水	8:24	19.4					7.8	1.4	
22	木	8:23	19.3					7.9	1.3	
23	金	8:23	20.6					7.6	3.1	
24	土	8:00	19.2					8.0	1.3	
25	日	8:00	18.4					7.8	1.3	
26	月	8:37	18.2	41	72	9.7	0.07	7.8	1.5	37.0
27	火	8:25	17.9					7.7	2.1	
28	水	8:23	17.8					7.9	1.5	
29	木	8:23	18.5					7.9	2.1	
30	金	8:24	18.6					8.4	1.5	
31	土	8:00	19.6					8.2	2.2	
平均		—	17.0	40	68	9.2	0.06	7.8	1.9	35.7
最高		—	20.6	41	72	9.7	0.08	8.4	4.5	37.0
最低		—	14.3	39	64	8.9	0.04	7.5	1.3	34.6
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和7年6月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	°C	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	日	8:00	19.2					7.8	3.6	
2	月	8:28	18.2	37	67	9.0	0.03	8.2	1.4	34.8
3	火	8:44	18.1					8.1	1.5	
4	水	8:22	18.4					8.1	1.9	
5	木	8:40	18.3					8.3	1.4	
6	金	8:22	18.7					8.4	1.7	
7	土	8:00	19.2					8.5	1.6	
8	日	8:00	19.7					8.5	1.8	
9	月	8:40	20.1					8.9	1.5	
10	火	8:28	20.9	37	65	8.9	<0.03	8.9	1.1	34.4
11	水	8:23	20.7					8.7	2.0	
12	木	8:23	20.4					7.9	6.9	
13	金	8:25	19.6					7.8	6.0	
14	土	8:00	20.0					7.9	3.8	
15	日	8:00	20.7					8.5	2.5	
16	月	8:26	20.8	38	68	8.4	0.09	8.3	2.4	36.3
17	火	8:41	22.3					8.0	2.2	
18	水	8:23	22.9					8.2	1.9	
19	木	8:24	23.2					8.5	1.7	
20	金	8:25	22.8					7.8	2.1	
21	土	8:00	23.5					8.4	1.8	
22	日	8:00	25.1					8.4	1.4	
23	月	8:24	25.6	38	63	8.7	0.04	8.4	1.1	35.0
24	火	8:39	23.9					7.8	2.4	
25	水	8:24	24.4					7.7	1.9	
26	木	8:26	24.2					7.7	2.2	
27	金	8:23	24.6					7.9	2.4	
28	土	8:00	23.4					8.2	1.7	
29	日	8:00	24.9					8.0	2.3	
30	月	8:24	25.8					8.3	1.7	
-	-									
平均		—	21.7	38	66	8.8	0.04	8.2	2.3	35.1
最高		—	25.8	38	68	9.0	0.09	8.9	6.9	36.3
最低		—	18.1	37	63	8.4	<0.03	7.7	1.1	34.4
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和7年7月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	火	8:00	19.2	36	69	9.0	0.04	7.8	3.6	34.3
2	水	8:23	26.5					8.4	1.4	
3	木	8:24	27.4					8.4	1.1	
4	金	8:23	25.9					8.1	1.5	
5	土	8:00	26.7					7.8	1.6	
6	日	8:00	26.0					7.9	1.6	
7	月	8:22	26.8	37	66	9.0	<0.03	8.0	1.6	35.8
8	火	8:39	28.5					8.1	1.1	
9	水	8:21	29.1					8.1	1.1	
10	木	8:23	29.4					8.1	1.0	
11	金	8:42	28.7					7.4	1.8	
12	土	8:00	29.7					7.8	1.3	
13	日	8:00	29.5					7.9	1.3	
14	月	8:25	29.3	37	68	8.9	<0.03	7.9	1.4	34.6
15	火	8:26	28.9					8.0	1.3	
16	水	8:25	28.7					8.0	1.3	
17	木	8:23	28.3					7.9	1.6	
18	金	8:22	28.0	36	65	9.0	<0.03	7.9	1.4	35.5
19	土	8:00	27.8					8.0	1.1	
20	日	8:00	27.4					7.9	1.3	
21	月	8:00	27.9					7.9	1.3	
22	火	8:26	28.1					7.7	1.5	
23	水	8:39	29.1					7.9	1.1	
24	木	8:23	29.1					7.7	1.1	
25	金	8:25	29.1					7.9	0.9	
26	土	8:00	29.9					7.8	1.3	
27	日	8:00	29.3					7.9	1.0	
28	月	8:23	30.1	36	66	9.0	<0.03	7.8	1.1	35.0
29	火	8:37	30.4					7.8	1.1	
30	水	8:23	30.6					7.8	1.0	
31	木	8:24	30.8					7.7	1.0	
平均		—	28.3	36	67	9.0	<0.03	7.9	1.3	35.0
最高		—	30.8	37	69	9.0	0.04	8.4	3.6	35.8
最低		—	19.2	36	65	8.9	<0.03	7.4	0.9	34.3
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和7年8月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	°C	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	金	8:23	31.3					7.8	0.9	
2	土	8:00	31.4					7.8	1.1	
3	日	8:00	30.7					7.7	1.2	
4	月	8:41	30.7	38	65	8.8	<0.03	7.8	1.2	34.8
5	火	8:23	31.5					7.8	0.9	
6	水	8:22	31.0					7.6	1.1	
7	木	8:24	30.1					7.6	1.2	
8	金	8:25	30.3					7.8	1.3	
9	土	8:00	30.0					7.7	1.2	
10	日	8:00	29.6					7.7	1.2	
11	月	8:00	29.0					7.7	1.2	
12	火	8:00	28.8					7.8	1.0	
13	水	8:00	28.8					7.8	1.0	
14	木	8:00	28.8					7.6	1.3	
15	金	8:00	29.2					7.6	1.2	
16	土	8:00	29.5					7.5	1.4	
17	日	8:00	29.9					7.7	1.2	
18	月	8:27	29.8					7.6	1.1	
19	火	8:27	29.8	41	67	9.0	0.03	7.6	1.2	34.2
20	水	8:23	30.3					7.6	1.0	
21	木	8:24	30.2					7.5	1.1	
22	金	8:24	30.6					7.7	1.0	
23	土	8:00	30.7					7.7	0.9	
24	日	8:00	30.7					7.5	1.1	
25	月	8:24	30.9	38	71	9.5	<0.03	7.6	1.0	36.9
26	火	8:24	31.3					7.7	0.9	
27	水	8:23	31.0					7.7	0.9	
28	木	8:24	30.6					7.8	0.9	
29	金	8:24	30.7					7.6	1.0	
30	土	8:00	30.7					7.8	0.9	
31	日	8:00	30.7					7.7	0.9	
平均		—	30.3	39	68	9.1	<0.03	7.7	1.1	35.3
最高		—	31.5	41	71	9.5	0.03	7.8	1.4	36.9
最低		—	28.8	38	65	8.8	<0.03	7.5	0.9	34.2
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和7年9月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	°C	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	月	8:23	31.0	40	69	8.9	<0.03	7.8	1.0	35.6
2	火	8:26	31.2					7.8	0.9	
3	水	8:24	31.3					7.9	0.9	
4	木	8:23	31.0					7.5	1.1	
5	金	8:24	30.5					7.7	1.0	
6	土	8:00	30.1					7.9	1.2	
7	日	8:00	29.8					7.9	1.2	
8	月	8:25	30.3	39	70	8.9	<0.03	7.9	1.0	35.6
9	火	8:28	30.3					7.9	1.1	
10	水	8:24	30.4					7.9	1.2	
11	木	8:23	30.0					7.8	1.2	
12	金	8:25	29.6					7.9	1.1	
13	土	8:00	29.1					7.9	1.1	
14	日	8:00	29.3					7.9	1.1	
15	月	8:00	29.2					7.9	1.0	
16	火	8:26	29.4	37	72	8.9	0.04	8.0	1.2	35.4
17	水	8:25	29.4					7.8	1.2	
18	木	8:24	29.6					7.9	1.1	
19	金	8:20	28.9					8.1	1.4	
20	土	8:00	28.9					8.1	1.4	
21	日	8:00	28.4					7.9	1.4	
22	月	8:23	26.7					7.8	3.9	
23	火	8:00	27.0					8.0	1.6	
24	水	8:24	26.9	39	74	9.4	0.19	8.1	1.6	34.3
25	木	8:28	26.6					8.0	1.7	
26	金	8:24	26.4					8.0	1.7	
27	土	8:00	26.2					8.1	2.5	
28	日	8:00	25.5					8.3	2.1	
29	月	8:27	25.9	37	72	9.3	0.05	8.1	2.0	37.0
30	火	8:24	25.0					8.0	2.0	
-	-									
平均		—	28.8	38	71	9.1	0.06	7.9	1.4	35.6
最高		—	31.3	40	74	9.4	0.19	8.3	3.9	37.0
最低		—	25.0	37	69	8.9	<0.03	7.5	0.9	34.3
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和7年10月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	水	8:25	25.2					8.0	1.4	
2	木	8:24	24.5					8.1	1.7	
3	金	8:24	24.9					8.1	1.8	
4	土	8:00	24.2					8.0	1.6	
5	日	8:00	24.0					7.8	1.6	
6	月	8:25	24.3	38	66	9.0	<0.03	7.9	1.3	36.9
7	火	8:25	24.6					7.9	1.9	
8	水	8:23	24.5					7.9	1.6	
9	木	8:23	24.8					7.9	3.3	
10	金	8:23	23.1					7.7	3.2	
11	土	8:00	23.7					7.7	1.9	
12	日	8:00	24.3					7.8	1.8	
13	月	8:00	24.4					7.8	1.5	
14	火	8:26	23.6	38	65	9.1	0.09	7.6	1.9	36.5
15	水	8:23	23.9					7.6	1.9	
16	木	8:23	23.9					7.8	1.5	
17	金	8:23	23.3					7.8	2.8	
18	土	8:00	23.3					7.8	2.0	
19	日	8:00	22.7					7.8	2.9	
20	月	8:26	22.5	40	69	9.3	0.04	7.8	2.0	36.6
21	火	8:21	20.7					7.7	6.1	
22	水	8:23	19.5					7.8	2.4	
23	木	8:45	19.6					7.8	1.4	
24	金	8:25	19.9					7.8	1.7	
25	土	8:00	20.1					7.9	1.4	
26	日	8:00	20.6					7.9	1.6	
27	月	8:21	20.2	39	68	9.0	0.11	7.8	2.6	36.5
28	火	8:20	19.1					7.7	1.9	
29	水	8:24	17.2					7.8	3.4	
30	木	8:21	17.5					7.8	3.0	
31	金	8:24	18.3					7.8	2.6	
平均		—	22.3	39	67	9.1	0.06	7.8	2.2	36.6
最高		—	25.2	40	69	9.3	0.11	8.1	6.1	36.9
最低		—	17.2	38	65	9.0	<0.03	7.6	1.3	36.5
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和7年11月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	℃	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	土	8:00	17.8					7.8	3.0	
2	日	8:00	17.3					7.7	2.6	
3	月	8:00	17.2					7.8	2.6	
4	火	8:21	15.9	41	67	9.4	0.05	7.8	2.6	37.9
5	水	8:22	17.1					8.0	2.0	
6	木	8:24	16.7					7.9	1.9	
7	金	8:22	17.3					7.8	2.3	
8	土	8:00	16.1					7.8	3.1	
9	日	8:00	17.3					7.9	1.7	
10	月	8:23	17.2					7.8	1.6	
11	火	8:24	16.3	40	67	9.1	0.05	7.8	1.9	36.7
12	水	8:38	15.5					7.8	1.9	
13	木	8:19	15.9					7.9	1.6	
14	金	8:23	15.8					7.8	1.5	
15	土	8:00	15.5					7.8	1.4	
16	日	8:00	15.4					7.8	1.7	
17	月	8:16	15.9	39	65	9.1	<0.03	7.8	1.5	36.0
18	火	8:24	16.0					7.8	2.2	
19	水	8:41	14.6					7.8	2.2	
20	木	8:21	14.0					7.8	1.7	
21	金	8:19	14.4					7.9	1.5	
22	土	8:00	15.0					7.8	3.0	
23	日	8:00	14.3					7.8	3.1	
24	月	8:00	14.3					7.9	3.0	
25	火	8:21	14.7	39	64	9.1	<0.03	7.8	3.0	36.5
26	水	8:21	14.5					7.8	2.9	
27	木	8:22	14.2					7.8	3.2	
28	金	8:22	14.9					7.8	2.8	
29	土	8:00	14.3					7.8	3.1	
30	日	8:00	13.9					7.8	2.8	
-	-									
平均	—		15.6	40	66	9.2	0.03	7.8	2.3	36.8
最高	—		17.8	41	67	9.4	0.05	8.0	3.2	37.9
最低	—		13.9	39	64	9.1	<0.03	7.7	1.4	36.0
記事										

水道施設管理集計表（水質検査等）

彦根浄水場（工業用水）

令和7年12月

		採水時刻	水温	硬度	蒸発残留物	塩素イオン	鉄イオン	pH値	濁度	総アルカリ度
日	曜	時：分	°C	mg/L	mg/L	mg/L	mg/L		度	mg/L
1	月	8:23	14.1					7.8	2.6	
2	火	8:28	14.5	39	69	9.1	0.05	7.8	2.6	35.6
3	水	8:20	14.7					7.9	3.0	
4	木	8:20	11.8					7.8	5.9	
5	金	8:20	11.7					7.8	3.4	
6	土	8:00	11.8					7.8	3.2	
7	日	8:00	11.7					7.8	2.9	
8	月	8:20	12.1	39	71	9.1	0.05	7.8	2.2	36.2
9	火	8:20	12.2					7.9	2.9	
10	水	8:36	11.8					7.9	2.5	
11	木	8:16	11.9					7.9	2.5	
12	金	8:19	11.6					7.8	4.3	
13	土	8:00	10.5					7.9	3.4	
14	日	8:00	11.9					7.8	2.6	
15	月	8:20	11.2	40	66	9.3	0.08	7.9	3.2	37.0
16	火	8:21	11.0					7.9	2.7	
17	水	8:20	11.2					7.8	2.5	
18	木	8:20	11.2					7.8	2.9	
19	金	8:14	10.0					7.9	3.1	
20	土	8:00	11.2					7.9	2.4	
21	日	8:00	11.8					7.8	2.6	
22	月	8:19	11.1	41	68	9.9	0.07	7.8	3.2	37.7
23	火	8:27	10.0					7.9	2.7	
24	水	8:18	11.3					7.7	2.1	
25	木	8:19	11.7					7.8	2.2	
26	金	8:20	10.2					7.8	3.8	
27	土	8:00	8.8					7.7	3.1	
28	日	8:00	9.5					7.7	2.2	
29	月	8:00	9.0					7.7	2.3	
30	火	8:00	9.8					7.7	2.4	
31	水	8:00	10.0					7.7	2.6	
平均		—	11.3	40	69	9.4	0.06	7.8	2.9	36.6
最高		—	14.7	41	71	9.9	0.08	7.9	5.9	37.7
最低		—	8.8	39	66	9.1	0.05	7.7	2.1	35.6
記事										